**Cerberus Division** 

# SIEMENS CP-35

# System 3<sup>™</sup> Control Panel

# ENGINEER AND ARCHITECT SPECIFICATIONS-

- Basic Two Zone System
- Expandable
- Double Supervision
- Ground Detection
- Supervised Alarm Relay Coil
- Listed, ULC Listed, FM, CSFM and NYMEA Approved



## Description

The Cerberus Pyrotronics control panel model CP-35 is the basic control unit for the System 3 universal alarm control. It is of solid state circuitry and is designed for use in commercial, institutional, industrial and life safety applications. The unit is Underwriters Laboratories, Inc. listed and FM approved for service in accordance with

NFPA 72. The system is also UL listed for waterflow alarm with supplementary modules included in the system.

The model CP-35 and its associated PS-35 (Power Supply) provide circuitry for two supervised initiating device circuits, wired for either Class A or Class B (Styles D or B respectively). The CP-35 control panel accommodates any of Cerberus Pyrotronics conventional lowvoltage detectors, manual stations or contact type input devices. The CP-35 also incorporates one supervised notification appliance circuit utilizing either 120 VAC or 24 VDC devices. The notification appliance circuit can be wired in either a Class A or B (Styles Z or Y respectively) configured when using 24 VDC devices. If 120 VAC devices are used, the circuit can only be wired as a Class B (Style W) circuit.

The two initiating zones within the CP-35 are power limited per NFPA 70. With the addition of a PLM-35 module, the notification appliance circuit also becomes a power limited circuit. Nine visual system indicators are mounted on the face of the CP-35, a green Power On LED, a red Alarm LED, a yellow Trouble LED and a yellow Ground Fault LED. To monitor the two detector circuits, a red Zone Alarm LED and a yellow Zone Trouble LED are supplied for each zone. An additional yellow Audible Signal Circuit Trouble LED is also provided.

Two momentary contact switches are mounted on the CP-35, one serving as a combination "Reset/LampTest" function, while the other permits "Alarm Silence." A fixed two position "Trouble Silence" switch and an internal trouble signal sounding device is provided. A remotely located Alarm and Trouble Annunciator (RTA-38) is optional.

# Operation

## Power

The combination of a Model CP-35 with a PS-35, operates from a three-wire, 120/240 VAC 50/60 Hz supply with grounded neutral, incorporating double supervision. Secondary power may be supplied with option standby battery. The green Power LED is illuminated to show that power is normal. Each input power line is separately fused within the power supply.

Loss of the main AC operating power or secondary AC supervisory power is signaled by the system audible and yellow visual trouble LED. Restoration of power returns the panel to normal condition. When standby battery is



specified, loss of main power results in an audible and visual trouble signal and the batteries provide power to the system.

The system power supply furnishes power for detector circuits and audible signal circuits. The detector circuits may be the two zones incorporated in the CP-35 control, plus any mix of additional compatible zones, signal circuits or other fire monitoring circuits. In addition, an output rated at 24 VDC 1.5A is provided on terminals 5 and 6 of the PS-35 for powering modules internally housed and wired within the control unit enclosure.

#### Alarm

The control panel alarm section circuitry responds to any zone module alarm input signal either from the on-board zones or separate zone modules. The alarm condition is "Locked In" within the control panel and is cleared only by operation of the control panel "Reset" switch. An alarm condition is indicated by:

- Change of state of the two SPDT alarm relay contacts.
- 2. Illumination of the panel "Alarm" visual indicator.
- 3. Energizing of both the silenceable and nonsilenceable alarm outputs.
- 4. High going current-limited alarm signal.
- Alarm signal output to the remote alarm and silence station. Operation of the momentary "Alarm Silence" switch causes both the silenceable alarm

de-energize and the visual alarm

output to

#### indicator to flash.

#### Subsequent Alarm

After operation of the "Alarm Silence" switch following a system alarm condition, the system visual indicator operates in a flashing mode. A subsequent alarm input from a different zone will cause a renewed high going signal on the silenceable alarm output terminal, causing the associated or connected audible devices to be energized again. This operation may be repeated for up to ten (10) subsequent alarm conditions.

Simultaneous alarm input signals from two or more zone modules are considered to be but a single alarm input signal. Operation of the panel mounted alarm silence switch when no alarm is present has no effect. Operation of the key-operated momentary remote alarm station silence switch will cause a system trouble condition when the panel is not in an alarm condition.

#### Trouble

A trouble condition in CP-35 will be caused by any of the following:

An open initiating device circuit or initiating device out of place

- An open in the municipal tie circuit
- An open or short on a notification appliance circuit Removal of a supervised system module
- Loss of main power and/or secondary power if equipped with additional backup
- Any ground fault within the system or its wiring Auxiliary power output fuse open or missing (see PS-35)

- The momentary reset switch not in its fully closed position
- Failure of the 12VDC logic power supply
- Alarm relay coil open
- Loss of 120 VAC trouble phase input supply
- Key-operated remote alarm station silence switch in
- off-normal position when system is not in alarm Battery charger/transfer module fault condition
- Battery charger/transfer module fault condition

CP-35 trouble conditions are annunciated by the following actions:

- CP-35 "Trouble" LED illuminates
- CP-35 built-in trouble buzzer sounds
- Trouble relay, SPDT contacts, changes state
- High going, current limited trouble output, Term 43 is energized
- Trouble output to RTA-38, Term's 22-26, is energized

The control panel audible trouble buzzer may be silenced by the control panel trouble silence switch or the remote trouble silence station switch, when used. Trouble ringback of this buzzer is provided to indicate that either the control panel trouble silence switch or the remote trouble station trouble silence switch is in the off-normal or silence position when no panel trouble condition is present.

### Flexibility

The use of the Cerberus Pyrotronics control panel model CP-35 permits expansion of system capability to incorporate additional functions over and above the two zone actuation circuits and visual and audible annunciating devices provided with the basic panel. The CP-35 will accommodate a combination of the following options:

- Multiple alarm priorities
- Master Code
- Municipal tie with disconnect light and switch
- Remote station connection with disconnect light and switch
- Time limit cut out with indicator
- Supplementary relays
- Battery standby
- Remote alarm and Trouble silence
- Non-fire monitoring
- Reconfirmation
- Halon release, FM 200™
- Multiple notification appliance circuits
- Pre-action/deluge sprinkler control

## Engineer and Architect Specifications

The control panel for the alarm system shall be Cerberus Pyrotronics model CP-35. It shall be listed by Underwriters Laboratories, Inc.

The panel shall provide power and necessary components for the operation of the basic two zones of supervised detector circuits and one supervised notification appliance circuit utilizing 24 VDC devices. The detector circuit shall accommodate ionization, photoelectric, flame or thermal detectors as well as shorting type contact devices intermixed as desired on the same zone.

The model CP-35, with a PS-35, shall operate from a three-wire 120/240 VAC 50/60 Hz supply. Each input shall be separately fused within the panel. It shall include

LEDs for system power, alarm, and trouble as well as LED indicators for zone alarm, zone trouble and audible signal circuit trouble.

Momentary contact switches shall be provided for "Reset/LampTest" and "Trouble Silence" which shall silence the internal trouble signal sounding device. Alarm receipt shall override trouble.

The control panel shall be capable of powering early warning detectors and audible signal circuits. Additional circuitry and visual signaling for this capability shall be provided by Cerberus Pyrotronics "Add-On" modules and enclosures as are necessary. Interconnection of these modules to the CP-35 shall be by ten-plug and harness assemblies which shall provide system power, supervision, lamp-testing functions and such other circuitry as is necessary for an operable system. The control panel shall have two (2) sets of normally open and normally closed alarm operated relay contacts and one (1) set of normally open and normally closed trouble operated relay contacts. All contacts shall be rated at 120 VAC/30 VDC, 3 Amp. The alarm relay coil shall be supervised. In addition, the panel shall have built-in ground detection as well as plug-in connectors for emergency power. It shall be arranged so that alarm signal annunciation shall take precedence over a trouble signal. Terminals shall be provided so that the trouble indicators and controls can be located remotely.

The model CP-35 shall permit expansion of system capabilities to incorporate any combination of compatible Cerberus Pyrotronics System 3 modules not exceeding the maximum current demand.

## **Ordering Information**

The model CP-35 occupies space normally taken by five (5) modules and must be located in the upper left-hand position of any type enclosure. This should be considered when sizing the enclosure.

Model No.	Description	Shipping Wt.	Part No.
CP-35	Control Panel w/ 2 zones and 1 universal signal circuit	6lb. (3.7kg.)	500-884879
PS-35	Power Supply for the CP-35	16lb. (8.3kg.)	500-884950
PLM-35	Power Limiting Module for the CP-35 audible circuit	6oz. (.2kg)	500-893490

## **Electrical Information**

Power Requirement: 120/240 VAC, 50/60 Hz, three-wire

The model CP-35 is normally mounted on rail/brackets, separately priced, for installation in the enclosures. Each enclosure requires a rail/bracket assembly kit of appropriate size. The size of the enclosure therefore must be noted at the time of order. Rail/bracket assembly kits are shown below.

Rail/Bracket Assembly Kit	Enclosure	Door	Module Spaces
EK-31	EB-31	ED-31	8
EK-32	EB-32	ED-32	16
EK-33	EB-33	ED-33	24
EK-35	EB-35	ED-35	40

**Note:** Please refer to the System 3 Enclosure Specification Sheet No. 3325 for additional information and options.

## Typical Wiring



(velow) in P2, and Model EL31 with end of line device. Note: When Class A audible circuit configuration 5 is used, 24 VDC audible devices are required. 2. Connect the silenceable System Alarm output signal, terminal 36, the at/KA-30U modules. Connect the non-silenceable system alarm output signal, terminal 5 of the AE/A-30U modules. Connect the non-silenceable system alarm output signal, terminal 42, to such modules as the MT-30, LP30, and SR-35. When other alarm signals such as coding or time limit are required, see individual module instruction sheets. 3. When water flow devices are used, employ non-silenceable system alarm output signal TB1, terminal 42, to energize audible alarm device circuits.

Audible alam device circuits may be coded by using coder modules NG3 or ZC-30.
Audible alam device circuit signal duration may be limited by using the time limit cutout module Model IT-200.

Refer to battery manufacturer's instructions for maintenance and test of System batteries when

maintenance and test of System batteries when applicable. Refer to appropriate module instructions for specific information. The maximum line resistance should be 3 ohms, and a minimum of 14 AVVG wire is recommended. All wiring should comply with the local and national codes that apply to the particular installation.

Siemens Building Technologies **Cerberus Division** 

Callerins the sum of that wrinus modules and (b) terminals 5 and 6 of the power supply module and all audible alarm device circuits when DC audible devices are used. **Under no circumstances should** these given maximum current values be

exceeded. 10.COMPATIBLE NOTIFICATION APPLIANCES, refer to P/N 315-096363

P/N 315-096363 11Axxillary output is rated 24 VDC. Nominal, 15A max for internal application such as SR-32, SR-35, SR-35, or Model RA annunciator located within control unit enclosure(s). (See Note 9 for total current rating.) 12. See individual detector instructions for actual terminal connection numbers. Maximum of 30 detectors per circuit allowed. (Only one PBA-1191 may be used per circuit allowed.

circuit.) 13.To use power limited wiring to NFPA 70, NEC Article 760, the audible circuits (terminals 32 and 35) must use the PLM-35 module. Refer to Instructions P/N 015.002405

als-0a345. 14.Connect the following modules only: AA:30U, AD-a) 30S, AE:30U, HC:30U, HC:35, DS:30, LP:30, MC:30, MT:30, PM:31, PM:32, RM:30U, RM:30RU, SM:30, SR:30, SR:32, SR:35, TL:30U, ZC:30, and ZC:31. (5) Shot, Shot, New York, Shot, Yeson, Status, Shot, Shot

> Cerberus Division 8 Fernwood Road Florham Park, NJ 07932 Tel: (973) 593-2600 FAX: (973) 593-6670 Website: www.cerbpyro.com

4/00 10M SCD-IG Printed in U.S.A. Cerberus Division 50 East Pearce Street Richmond Hill, Ontario L4B, 1B7 CN Tel: (905) 764-8384 FAX: (905) 731-9182

NOTICE: The use of other than Cerberus Pyrotronics control equipment will be considered a misapplication of Cerberus Pyrotronics equipment and as such void all warranties either expressed or implied with regards to loss, damage, liabilities and/or service problems.

> April 2000 Supersedes sheet dated 8/98