


Replacement for Simplex® 6310-9231 Synchronous-Wired Corrective 59th Motor Movement

FEATURES

- Complete with correction coil
- Set hands at 5:59 when replacing



DESCRIPTION

These corrective movements perform a 12 hour correction twice daily at 5:57:54 with a 14 second pulse from the system master clock. Hourly correction is performed at HH:57:54 with an 8 second correction pulse.

ORDERING INFORMATION

Part #	Description
N1276	120vac

SPECIFICATIONS

Operating Voltage - N1276

120vac/120vac 60 Hz Run .055 amps Correction coil = .023 amps

At Life Safety Consultants, we continually strive to improve our products to meet our customers' needs and to provide the best possible value. The above specifications are believed to be correct, are subject to change without notice and may otherwise vary from the above. Please call if you need verification of any specifications or the suitability of a particular product for a particular application. © Life Safety Consultants